

CERTIFICATE OF COMPLIANCE

Certificate Number 20171110-E230865
Report Reference E230865-20151013
Issue Date 2017-NOVEMBER-10

Issued to: TURCK INC
3000 CAMPUS DR
MINNEAPOLIS MN 55441-2619

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

Associated Apparatus, only for installation in non-hazardous (unclassified) locations
Flow Module, models FMX followed by -; followed by IM; followed by -; followed by 3UP or 2UPLi; followed by 63; followed by a single alphanumeric character; followed by X, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G and Class III hazardous locations when installed in accordance with Turck Control Drawing No. IS-1.316

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:


UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations.
CAN/CSA C22.2 No. 157-92, Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

