


# FCIC-G1/4A4P-AP8-H1141/0.5

# Flow Monitoring – Compact Inline Flow Sensors of the FCIC Series


# Transistor Output 24 VDC PNP NO




#### **Features**

- ■Thermodynamic operating principle
- If low monitoring of water
- Ready for use, no alignment
- Switchpoint water (on) 0.5 l/min
- Hysteresis (on/off) 0.05 l/min
- Operating voltage side polarized
- Transistor switching output
- ■24 VDC PNP NO
- Compact design
- Incl. adapter

## Wiring diagram





#### Functional principle

The FCIC inline flow sensors operate on the thermodynamic principle.

Depending on the version the sensors detect aqueous media from 0.05 to 2 l/min. In addition to the classic transistor switching output there is also a linear 4 ... 20 mA and a linear pulse output available with a clock rate of 1 ml/pulse.

The sensors are already pre-configured and must no longer be matched by the customer. They are therefore immediately ready for operation

To ensure a linear signal over the entire coverage, the sensors must be operated with the supplied adapter. The sensors with analog and pulse output provide a linear signal proportional to the flow rate in the specified operating range. However, it must be noted that water additives can lead to linear deviation

In addition, the stable and small-scale design makes the sensors resistant to moisture and vibration. It also simplifies the integration into already existing and new applications. Not least in hard-to-reach places the FCIC play to their strengths.



## Mounting instructions

Mounting adapter	All sensors of the FCIC series are used with an adapter. This ensures a linear signal over the entire coverage. The adapter is screwed on to the process connection at the infeed side.
Mounting position	In order to minimize potential misinterpretations due to disturbance, it is recommended to position the sensor with a minimum separation distance of 3 x di before and 5 x di after bends, changes in cross section, valves, etc  If deposits are likely to built up, it is recommended to clean the sensor at regular intervals and to select the associated service interval accordingly.  If the sensor is mounted in vertical piping systems, it is recommended to position the sensor within the riser.

#### Accessories

